



Consulting Enterprises in Technology

SCIENTIFIC CONSULTANTS IN RISK ASSESSMENT AND MANAGEMENT, PRODUCTS, PROCESSES, OH&S, ENVIRONMENT

# Emission Test Certificate

Monday September 22<sup>nd</sup>, 2008

Supplier: Verosol Australia Pty Ltd

2 Garema Circuit

Kingsgrove New South Wales 2208

Sample Description: Enviroscreen Trevira CS (fabric for roller blinds)

Date Tested: September 2008

Test Method: ASTM D5116 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

## Enviroscreen Trevira CS

Total Volatile Organic Compound Emission Rate:  $<0.05 \text{ mg/m}^2/\text{hr}$  (7 days)

When this product is used in the typical manner in an office building the resulting airborne total volatile organic compound concentration can be less than  $0.25 \text{ mg/m}^3$  as specified by Green Building Council of Australia Green Star Office Interiors IEQ-11.

Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

CV080905